

Fire alarm control panel MCU304

EXT933

Order-No.: EXT933



Extinguishing board for 1 area

- for fire control panel MCU304.
- for direct controlling of an extinguishing system in an extinguishing area.
- for multirange extinguishing a controlling module is necessary for every:
extinguishing area (per valve).
- activation by conventional as well as by analogue detectors possible
- 4 monitored control lines for signal transmitter and solenoid valve
- 4 potential-free relay contacts
- Technical specification:
outputs: relay 4 x 30 V DC/ 1 A
monitored outputs: 4 x signaltransmitter: 24 V DC / 0,5 A
magnetic valve: 24 V DC/1 A
Installation: same place as LCB20